

# Pengembangan pencegahan kebakaran di gedung Asrama Haji Pondok Gede Jakarta Timur tahun 2012

Rifaudi Hidayanto, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20313447&lokasi=lokal>

---

## Abstrak

Skripsi ini membahas pengembangan pencegahan kebakaran di gedung Asrama Haji Pondok Gede Jakarta Timur tahun 2012. Objek perielitian ini ialah gedung panginapan D3 Asrama Haji Pondok Gede. Penelitian ini adalah penelitian kualitatif dengan desain deskriptif. Hasil penelitian ini berupa persentase kesesuaian pencegahan kebakaran berdasarkan standar. Persentase kesesuaian tersebut sebesar 45,38 persen. Dari hasil penelitian tersebut peneliti merekomendasikan pengembangan pencegahan kebakaran yang dibagi menjad pengembangan jangka pendek dan pengembangan jangka panjang.

.....This thesis discusses the development of tire prevention in the building of Asrama Haji Pondok Gede, East Jakarta in 2012. Object of this study is the building D3 Asrama Haji. The study is a descriptive qualitative research design. The results of this study the suitability of fire prevention in the percentage based on the standards. The compliance percentage of fire prevention is 45.38 percent. From these results, the researcher recommends the developments of fire prevention are divided into-trmn development and long development.