

Analisis konsekuensi kebocoran, kebakaran dan ledakan pada spherical tank LPG di fasilitas pengolahan minyak dan gas PT Z = Leak fire and explosion consequence analysis on spherical tank in oil and gas processing facility of PT Z

Sahlur Hamzah Muksin, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20349005&lokasi=lokal>

Abstrak

Spherical tank yang berisi Butana merupakan subjek berpotensi hazard (kebocoran, kebakaran dan ledakan) yang dapat memberikan konsekuensi terhadap fasilitas dan manusia sebagai obyek penerima yang berada pada radius paparan. Penelitian ini menggunakan pemodelan dengan input data primer dan sekunder yang diaplikasikan dalam perangkat lunak ALOHA, Area Locations of Hazardous Atmosphere. Hasil penelitian terhadap skenario kejadian kebocoran, kebakaran dan ledakan di fasilitas pengolahan minyak dan Gas PT Z mendapatkan nilai konsekuensi zona bahaya sampai radius satu kilometer. Zona aman setelah radius satu kilometer.

.....

Spherical tanks containing Butane is subject of potentially hazard (leak, fire and explosion) which can bring facility and human consequences as the recipient objects which are in the radius of exposure. This research uses input modeling with primary and secondary data which applied in the Area Locations of Hazardous Atmosphere (ALOHA) software. The study of the leak, fire and explosion incidence scenario at oil and gas processing facilities of PT Z scores shows threat zone to a radius of one kilometer. Safety zone distance after radius kilometer.