

Tinjauan akustik ruang pada bangunan masjid. studi kasus: Masjid Jami Al-Istiqomah Tegal Parang = Acoustic review in the mosque building case study Jami Al-Istiqomah Mosque Tegal Parang

Nur Hikmah, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20429670&lokasi=lokal>

Abstrak

Masjid umumnya digunakan untuk tempat shalat, baik berjamaah atau sendiri. Masjid juga digunakan sebagai tempat menuntut ilmu agama, syiar Islam dan kegiatan sosial lainnya. Terdapat faktor yang mempengaruhi komunikasi dan kenyamanan pendengaran bagi jemaah masjid dan penceramah (guru atau khatib), yaitu faktor lingkungan seperti akustik.

Penelitian ini membahas mengenai keadaan akustik bangunan masjid serta kaitannya dengan kenyamanan pendengaran para jemaah pada saat shalat dan kegiatan pengajian berlangsung.

Hasil penelitian yang dilakukan dalam pengukuran waktu dengung (RT) dan kekerasan bunyi di Masjid Jami Al-Istiqomah Tegal Parang pada saat kosong (tidak ada jemaah) dan penuh dengan jemaah ketika acara Malam Nisfu Sya'ban di masjid tersebut, menunjukkan bahwa masjid tersebut belum memenuhi kriteria akustik yang baik untuk mendukung kegiatan di dalam sebuah masjid.

Dari hasil penelitian yang didapat, selanjutnya penulis memberikan saran perbaikan akustik pada masjid tersebut agar memenuhi kriteria akustik yang baik untuk sebuah bangunan masjid.

<hr><i>Mosque is commonly used as praying site, either with companion or alone. Beside, it has another function for the youth to learn Islamic studies, both educational and social activity. There are some factors which might influence the communication and convinience inside mosque while in lecturing section for audience and the lecture (cleric), it is environmental factor such as acoustic.

This research is mainly discuss about the acoustic condition of the building and its connection with the convinience of audience while in both praying and reciting section.

The result an of investigation which have been observation about reverberation time and intensity of sound at Jami? Al-Istiqomah Mosque Tegal Parang while its empty (without any people inside) and while its full capacity when Night of Nisf Shabaan Ceremony, showed that the mosque is not fulfill the proper acoustic criteria yet, for supporting any activity inside the building.

From the results obtained, the authors further suggest ways to improve acoustics in the mosque in order to meet the criteria for good acoustics for a mosque.</i>