

Studi analisis potensi pemborosan energi listrik pada gedung ruang kuliah bersama 2 di Fakultas Teknik Universitas Indonesia = Study of potential analysis of waste of electrical energy at the building of joint classroom 2 at Faculty of Engineering Universitas Indonesia

Nandhika Azhardinan Noor, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20457120&lokasi=lokal>

Abstrak

Semakin langkanya sumber daya alam yang dibutuhkan untuk membangkitkan energi listrik membuat kita sebagai penggunanya melakukan penghematan energi listrik. Penelitian yang dilakukan pada tulisan ini bertujuan untuk mengetahui besarnya potensi pemborosan energi listrik pada salah satu gedung kuliah di Fakultas Teknik Universitas Indonesia sehingga dapat dilakukannya langkah-langkah penghematan terhadap pemborosan tersebut. Penelitian yang telah dilakukan menggunakan data hasil dari pengamatan terhadap pola operasi konsumsi energi listrik untuk mengetahui besar nilai penggunaan energi listriknya.

Besar potensi pemborosan energi dihitung dengan mengurangi penggunaan energi berdasarkan perbaikan teknis peralatan listrik dan perbaikan operasi penggunaan energi listrik. Sehingga, didapatkan besar nilai potensi pemborosan energi pada khususnya ruang kelas di Gedung Ruang Kuliah Bersama 2 FTUI sebesar 10553,5235 kWh/bulan dan total penghematan yang dapat dilakukan dalam rupiah yaitu sebesar Rp7.756.781,096.

.....The scarcity of natural resources needed to generate electrical energy makes us as users to save electricity. The research conducted in this paper aims to determine the magnitude of the potential waste of electrical energy in one of the lecture buildings at the Fakultas Teknik Universitas Indonesia so that it can be done austerity measures against the waste. The research that has been done using data from the observation of the operation pattern of electrical energy consumption to know the value of the use of electrical energy. The potential energy wastage is calculated by reducing energy use based on technical improvements of electrical equipment and improving the operation of electrical energy usage. Thus, the value of potential energy wastage in particular classrooms in the Building of Joint Classroom 2 Faculty of Engineering, Universitas Indonesia of 10553.5235 kWh month and total savings that can be done in rupiah amounting to Rp7.756.781,096.