

Analisis pengambilan keputusan menggunakan metode markov dalam penerapan manajemen aset di PT PLN. (Persero) transmisi Jawa Bagian Barat = Decision making analysis using the markov method in the application of asset management at PT. PLN (PERSERO) West Java transmission unit

Amanda Sri Lestari Putriyani, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20497727&lokasi=lokal>

Abstrak

Pengambilan keputusan dalam perusahaan sangat penting untuk mencapai tujuan perusahaan, mengoptimalkan biaya operasional, serta meningkatkan kualitas pelayanan terhadap konsumen. Analisis yang bersifat prediktif dapat dilakukan dengan melakukan pendekatan matematis sebagai salah satu sistem pendukung pengambilan keputusan, sehingga dapat dipilih keputusan yang paling tepat serta paling efektif dan berdampak besar terhadap permasalahan yang dihadapi, dan juga dapat mengurangi kerugian yang tidak diinginkan. Dalam penelitian ini, digunakan pemodelan markov untuk memprediksi usia operasi transformator, yaitu 34 tahun sebagai salah satu metode yang relevan dengan penerapan manajemen aset di PT. PLN (Persero) Transmisi Jawa Bagian Barat. Hasil pemodelan menunjukkan durasi pengoperasian transformator dari awal pemasangan sampai dengan fase disposal sehingga manajemen dapat melakukan langkah antisipatif untuk meminimalisir pemadaman listrik yang diakibatkan oleh penggantian peralatan, sehingga dapat meningkatkan kepuasan pelanggan serta meningkatkan keuntungan yang diperoleh perusahaan.<

<hr>

Decision making in the company is very important to achieve company goals, optimize operational costs, and improve the quality of service to consumers. The analysis that can be done can be done using mathematically as one of the decision-making support systems, so the management can choose the most appropriate, most effective and highly impact decision on the problems that are faced by the company and can also reduce undesirable loses. In this study, markov modelling was used to predict the age of transformer operation, the result is 34 years as one method that is relevant to the application of asset management at PT. PLN (Persero) Transmission West Java. The modelling results show estimation of transformer life duration from the beginning of the installation to its end of life. It also makes management able to make anticipatory steps to minimize the power outages that are included by equipment replacement, to increase customer satisfaction and increase the profits obtained by the company.