

# **Analisis Pengaruh Harmonis Dengan Pembebanan Non Linier Terhadap Deviasi Pengukuran Pada kWh Meter (Analog) = Analyze The Effect Of Harmonic With Non-Linear Load On Measurement Deviation On Analog Electricity Meter**

Debby Ramadhani, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20504521&lokasi=lokal>

---

## **Abstrak**

### **<b>ABSTRAK</b>**

kWh meter adalah alat yang sehari-hari dipakai oleh para konsumen. kWh meter digunakan untuk mengukur energi listrik yang dipakai dan harus dibayar oleh para konsumen. Pengukuran harus memiliki tingkat akurasi yang tinggi agar tidak merugikan. Tanpa disadari penggunaan beban non linier oleh para konsumen mempengaruhi hal tersebut. Penelitian ini dilakukan untuk melihat pengaruh harmonis terhadap kesalahan pengukuran pada kWh meter analog. Hasil penelitian ini menunjukan bahwa semakin besar nilai THD maka semakin besar nilai deviasi pengukuran pada kWh meter analog hingga mencapai 8.79%.

<hr>

### **<i><b>ABSTRACT</b>**

kWh meter is a tool used everyday by consumers. kWh meter is used to measure the electrical energy used and must be paid by consumers. Measurements must have a high degree of accuracy so as not to harm. Unwittingly the use of non-linear load by consumers affects this. This research was conducted to see the effect of harmonics on measurement errors on analog kWh meters. The results of this study indicate that the greater the THD value, the greater the measurement deviation value of the analog kWh meter up to 8.79%.<i/>