

Gambaran Sistem Proteksi Kebakaran, Sarana Penyelamatan Jiwa, dan Manajemen Kebakaran Di Rumah Sakit X Tahun 2020 = Implementation of Fire Protection System, Means of Escape, and Fire Management at X Hospital 2020

Maura Wilona Andanari, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20507377&lokasi=lokal>

Abstrak

ABSTRAK

Skripsi ini membahas mengenai gambaran penerapan sistem proteksi kebakaran, sarana penyelamatan jiwa, dan manajemen kebakaran pada Rumah Sakit X. Penelitian ini menggunakan desain penelitian observasional dengan pendekatan kualitatif. Objek pada penelitian ini adalah fasilitas sistem proteksi kebakaran aktif, sistem proteksi kebakaran pasif, sarana penyelamatan jiwa, dan manajemen kebakaran Rumah Sakit X. Pengumpulan data didapatkan melalui observasi, wawancara, dan telaah dokumen, serta menggunakan instrumen berupa checklist. Analisis data dilakukan dengan membandingkan kondisi aktual dengan standar dan peraturan yang berlaku. Standar dan peraturan yang digunakan dalam penelitian ini adalah NFPA dan Pedoman Teknis Di Bidang Bangunan dan Sarana Rumah Sakit, Kemenkes RI 2012. Hasil akhir data merupakan presentase tingkat pemenuhan standar dan kategori penilaian menurut Balitbang Departemen Pekerjaan Umum. Berdasarkan hasil penelitian, sistem proteksi kebakaran aktif memiliki nilai presentase tingkat pemenuhan 53% dengan kategori kurang, sistem proteksi kebakaran aktif memiliki nilai presentase tingkat pemenuhan 42% dengan kategori kurang, sarana penyelamatan jiwa memiliki nilai presentase tingkat pemenuhan 66,7% dengan kategori cukup baik, dan manajemen kebakaran memiliki nilai presentase tingkat pemenuhan 81% dengan kategori baik.

<hr>

<i>ABSTRACT</i>

This study discusses about implementation of fire protection system, means of escape, and fire management at X Hospital. The design of this study is a qualitative study with observative research method. The object of this study is active fire protection system facilities, passive protection system facilities, means of escape facilities, and fire management at X Hospital. Data collection is obtained by observation, interviews, and document review, also this study use an instrument in the form of checklist. Data analysis is perform by comparing actual condition with applicable standards and regulations. The standards and regulations used in this study is NFPA and Pedoman Teknis Di Bidang Bangunan dan Sarana Rumah Sakit, Ministry of Health Republic Indonesia 2012. The final result of this data are percentage of standards compliance and assessment categorieis according to Reasearch and Development Agency of Public Works Department. Based on the result of the study, active fire protection system has a percentage value of 53% fulfillment rate with deficient category, passive fire protection system has a percentage value of 42% fulfillment rate with deficient category, means of escape has a percentage value of 66,7% fulfillment rate with fairly good category, and fire management has a percentage value of 81% fulfillment rate with good category.</i>