

## Analisis sistem proteksi dan manajemen keselamatan kebakaran di Kantor Pusat PT XYZ Jakarta tahun 2022 = Analysis of fire protection system and fire safety management at the Head Office of PT XYZ Jakarta, 2022

Samiyah Salim, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20522817&lokasi=lokal>

---

### Abstrak

Sektor perkantoran yang berada pada bangunan bertingkat tinggi memiliki potensi bahaya dan risiko kebakaran yang signifikan. Penelitian ini memiliki fokus pada analisis sistem proteksi aktif, sistem proteksi pasif, sarana penyelamatan jiwa, dan manajemen keselamatan kebakaran di Kantor Pusat PT XYZ. Desain penelitian menggunakan studi observasional dengan pendekatan semi kuantitatif. Pengumpulan data melalui observasi langsung, wawancara, telaah dokumen, serta menggunakan instrumen lembar checklist. Analisis data dilakukan dengan membandingkan kondisi aktual terhadap Peraturan Menteri Pekerjaan Umum Nomor 26/PRT/M/2008, Peraturan Menteri Kesehatan No. 48 Tahun 2016, Peraturan Menteri Pekerjaan Umum No. 20 Tahun 2009, dan Standar Nasional Indonesia (SNI). Berdasarkan hasil penelitian, sistem proteksi kebakaran aktif memperoleh persentase tingkat kesesuaian sebesar 85,2% dengan kriteria baik, sistem proteksi kebakaran pasif memperoleh persentase tingkat kesesuaian sebesar 66,6% dengan kriteria cukup, sarana penyelamatan jiwa memperoleh persentase tingkat kesesuaian sebesar 91,5% dengan kriteria baik, serta manajemen keselamatan kebakaran memperoleh persentase tingkat kesesuaian sebesar 91,8% dengan kriteria baik. Secara umum, elemen sistem proteksi kebakaran dan manajemen keselamatan kebakaran di Kantor Pusat PT XYZ telah memenuhi peraturan dan standar dengan persentase rata-rata yaitu 83,7%.

.....The office sector located in high-rise buildings has the potential for significant fire hazards and risks. This study focuses on the analysis of active protection systems, passive protection systems, means of escape, and fire safety management at PT XYZ Head Office. The research design uses an observational study with a semi-quantitative approach. Data collecting is gathered through direct observation, interviews, document review, and using the checklist sheet instrument. Data analysis is performed by comparing the actual conditions with Peraturan Menteri Pekerjaan Umum Nomor 26/PRT/M/2008, Peraturan Menteri Kesehatan No. 48 Tahun 2016, Peraturan Menteri Pekerjaan Umum No. 20 Tahun 2009, and Standar Nasional Indonesia (SNI). According to the results of the study, the active fire protection system obtained a percentage level of conformity of 85,2% with good criteria, the passive fire protection system obtained a percentage level of conformity of 66,6% with sufficient criteria, means of escape obtained a percentage level of conformity of 91,5% with good criteria, and fire safety management obtained the percentage of conformity level of 91,8% with good criteria. In general, the elements of fire protection systems and fire safety management at PT XYZ Head Office have complied with regulations and standards with an average percentage of 83,7%.