

Analisis Kenyamanan Termal dan Akustik pada Panti Werdha (Studi Kasus: Panti Sosial Tresna Werdha Budi Mulia 1) = The Analysis of Thermal and Acoustic Comfort in Panti Werdha (Case Study: Panti Sosial Tresna Werdha Budi Mulia 1)

Sheila Maharani Eka Buana, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=20526830&lokasi=lokal>

Abstrak

Setiap manusia membutuhkan kenyamanan untuk menunjang aktivitas kesehariannya di dalam ruangan. Kenyamanan khususnya dalam arsitektur dapat dilihat melalui beberapa indikator yang saling terkait, seperti kenyamanan termal dan akustik. Tingkat kenyamanan setiap manusia berbeda-beda, tak terkecuali bagi para lansia, khususnya di panti werdha. Di panti werdha, beberapa faktor kenyamanan dianggap menjadi pertimbangan lebih berkaitan dengan penurunan atau perubahan yang terjadi pada lansia itu sendiri. Untuk memahami kriteria kenyamanan termal dan akustik di panti werdha, maka dilakukan studi kasus di Panti Sosial Tresna Werdha Budi Mulia 1. Penelitian dalam studi kasus ini dilakukan dengan melakukan kunjungan lapangan. Pengamatan dilakukan dengan mengukur dan menghitung parameter secara langsung. Kemudian dilakukan simulasi untuk mendukung data pengukuran dan menilai keefektivitasnya. Berdasarkan hasil kunjungan studi ditemukan masih terdapat beberapa kondisi ruangan yang belum memenuhi standar kenyamanan termal dan akustik. Hal ini disebabkan oleh beberapa faktor seperti material yang digunakan, orientasi bangunan, sistem bukaan atau ventilasi, buffer zone, dan aktivitas di dalamnya. Dalam menanggapi hasil ini, tiga hal yang dapat dipertimbangkan untuk meningkatkan kenyamanan termal dan akustik, yaitu jenis material, bukaan, dan penghalang (barriers).

.....Every human being needs comfort to support their daily activities in the room. Comfort, especially in architecture, can be seen through several interrelated indicators, such as thermal and acoustic comfort. The comfort level of every human being is different, not least for the elderly, especially in panti werdha. In panti werdha, several comfort factors are considered more related to the decline or changes that occur in the elderly themselves. In a way to understand the criteria for thermal and acoustic comfort in panti werdha, a case study was conducted at Panti Sosial Tresna Werdha Budi Mulia 1. The research in this case study was conducted by conducting study visits. The observations were made by measuring and calculating parameters directly. Then, simulations are carried out to support the measurement data and assess its effectiveness. Based on the results of the study visit, it was found that there were still some room conditions that did not meet the thermal and acoustic comfort standards. In this case, there are influencing factors such as the material used, the orientation of the building, the opening or ventilation system, the buffer zone, and the activities in it. Three things can be considered to increase thermal and acoustic comfort in response to these results: the type of material, openings, and barriers.