

Analisis Pemetaan Suhu Ruang Penyimpanan Obat Narkotika di PT. Kimia Farma Trading & Distribution Cabang Jakarta 1 = Analysis of Temperature Mapping of The Narcotics Drug Storage Room at PT. Kimia Farma Trading & Distribution Branch 1 Jakarta

Muhammad Mishbahus Surur, author

Deskripsi Lengkap: <https://lib.ui.ac.id/detail?id=9999920566955&lokasi=lokal>

Abstrak

Pemetaan suhu ruang penyimpanan merupakan langkah penting dalam menjaga mutu, khasiat, dan keamanan obat sesuai pedoman Cara Distribusi Obat yang Baik (CDOB). Penelitian ini dilakukan di ruang penyimpanan obat narkotika PT. Kimia Farma Trading & Distribution Cabang Jakarta 1 untuk mengevaluasi kesesuaian suhu penyimpanan. Pengumpulan data dilakukan menggunakan thermo data-logger RC-5 yang dipasang di area terpilih berdasarkan tingkat fluktuasi suhu. Data suhu dicatat setiap 30 menit selama 3 hari berturut-turut, kemudian dianalisis menggunakan perangkat lunak Elitech Log V7.2.1 dan Microsoft Excel. Hasil penelitian menunjukkan bahwa rata-rata suhu ruang penyimpanan pada area yang tidak langsung terpapar pendingin udara (thermo data-logger A) adalah 25,1°C, dengan suhu maksimum 25,4°C dan suhu minimum 25,0°C. Fluktuasi suhu sebesar 0,4°C mencerminkan kestabilan lingkungan penyimpanan. Namun, data pada area yang langsung terpapar pendingin udara (thermo data-logger B) tidak tersedia karena kendala teknis. Penelitian ini menyimpulkan bahwa suhu ruang penyimpanan narkotika di area yang dianalisis masih sesuai dengan standar CDOB. Namun, diperlukan pemetaan tambahan dengan jumlah data logger yang lebih banyak untuk memastikan kesesuaian di seluruh area penyimpanan. Evaluasi rutin perlu dilakukan untuk menjaga kualitas penyimpanan, terutama pada area dengan risiko fluktuasi suhu tinggi.

.....Temperature mapping of storage rooms is essential for maintaining the quality, efficacy, and safety of medications in accordance with Good Distribution Practices (GDP). This study was conducted in the narcotics storage room of PT. Kimia Farma Trading & Distribution Jakarta Branch 1 to evaluate storage temperature compliance. Data collection was performed using an RC-5 thermo data-logger installed in selected areas based on temperature fluctuation levels. Temperature readings were recorded every 30 minutes over 3 consecutive days and analyzed using Elitech Log V7.2.1 software and Microsoft Excel. The results showed that the average temperature in the storage area not directly exposed to air conditioning (thermo data-logger A) was 25.1°C, with a maximum temperature of 25.4°C and a minimum of 25.0°C. The temperature fluctuation of 0.4°C reflects stability in the storage environment. However, data from the area directly exposed to air conditioning (thermo data-logger B) was unavailable due to technical issues. This study concludes that the storage room temperature for narcotics in the analyzed area complies with GDP standards. However, additional mapping with more data loggers is required to ensure compliance across the entire storage area. Routine evaluations are recommended to maintain storage quality, especially in areas with high-temperature fluctuation risks.